


GOVERNMENT OF WEST BENGAL  
DIRECTORATE OF PUBLIC HEALTH ENGINEERING,  
OFFICE OF THE EXECUTIVE ENGINEER,  
SILIGURI WATER SUPPLY DIVISION,  
DISTRICT LABORATORY AT FULBARI,  
SILIGURI

**PHYSICAL AND CHEMICAL TEST REPORTS :**

Date of Collection	27.03.2023
Date of Analysis	27.03.2023
Date of Reporting	27.03.2023


SL. NO.	Parameters	Acceptable Limit	Cause of Rejection	RESULT	
				Place	Kasi Bari , Salbari
				Source	Aqua Guard
				Sender	Campion International School
1.	Turbidity (NTU)	1	10		0.92
2.	pH	7.0 to 8.5	<6.5 or > 9.2		6.94
3.	Colour (Hz)	5	25		0
4.	Total Alkalinity (mg/l)	200	600		22
5.	Toal Hardness (mg/l)	300	600		11
6.	Iron (mg/l)	0.1	1.0		0.02
7.	Chloride (mg/l)	200	600		0
8.	Chlorine (mg/l)	0.2	>1.0		0
9.	Fluoride (mg/l)	1.0	1.5		0
10.	Copper (mg/l)	0.05	0.5		0.01

\*The tests done with the Sample as deposited by the Party.  
Physical & Chemical Test Charge @ Rs. 900.00/ Sample



Chemist / Bacteriologist,  
District Laboratory,  
Fulbari, W.T.P.

Junior Engineer,  
Siliguri Water Supply Division,  
P.H. Engineering Dte.



Assistant Engineer,  
Siliguri Water Supply Division,  
P.H. Engineering Dte.

Memo No. 548 / 22-23 /SD:

Dated 27/03/2023

*Gunjan Sahasratala*

PRINCIPAL  
CAMPION INTERNATIONAL SCHOOL  
CBSE AFFILIATION CODE 2490218  
SCHOOL CODE 15570

CAMPION EDUCATIONAL AND  
WELFARE FOUNDATION  
SECRETARY